

# Lewisburg Water and Wastewater Water Quality Report 2025

## Is my drinking water safe?

Yes, our water meets all of EPA's health standards. We have conducted numerous tests for over 80 contaminants that may be in drinking water. As you'll see in the chart on the back, we only detected 8 of these contaminants. We found all of these contaminants at safe levels.

## What is the source of my water?

Your water, which is surface water, comes from Duck River, 9 miles North of town. Our goal is to protect our water from contaminants and we are working with the State to determine the vulnerability of our water supply to contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for the water supply serving this water system. The SWAP Report assesses the susceptibility of public water supplies to potential contamination. Water sources have been rated as reasonably susceptible (high), moderately susceptible (moderate) or slightly susceptible (low) based on geologic factors and human activities in the vicinity of the water source. The Lewisburg Water System sources rated as moderately susceptible to potential contamination.

An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed online at <https://www.tn.gov/environment/program-areas/wr-water-resources/water-quality/source-water-assessment.html> or you may contact the Water System or TDEC at 1-888-891-TDEC to obtain copies of specific assessments.

## Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. Community water systems are required to disclose the detection of contaminants; however, bottled water companies are not required to comply with this regulation. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, spring, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water:

- Microbial contaminants, such as viruses and bacteria which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and the Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

## How can I get involved?

**Our Water Board meets on the third Tuesday of each month, at 12:00 Noon at 100 Water St. Please feel free to participate in these meetings. Este informe contiene información muy importante. Tradúscalo o hable con alguien que lo entienda bien.**

## Cross Connection

Be aware and never connect your safe drinking water with a source that could be contaminated. This includes wells that have not been tested and garden hoses hooked to lawn chemicals. A back-siphonage of water or a faulty valve could allow dangerous chemicals to enter your safe drinking water supply. If you have a well or use chemicals that come in contact with the public's safe drinking water, you must install a backflow prevention device and have it tested annually to insure that it is in proper working condition. A backflow prevention device will separate and not allow your safe drinking water to come into contact with anything unsafe.

## Other Information

Due to all water containing dissolved contaminants, occasionally your water may exhibit slight discoloration. We strive to maintain the standards

to prevent this. We at Lewisburg Water and Wastewater work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

## Is our water system meeting other rules that govern our operations?

The State and EPA require us to test and report on our water on a regular basis to ensure its safety. We have met all of these requirements. We want you to know that we pay attention to all the rules.

**For more information about your drinking water, please call Trigg Cathey, General Manager, at 931-359-6831**

## Do I Need To Take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have under-gone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about not only their drinking water, but food preparation, personal hygiene, and precautions in handling infants and pets from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

## Water System Security

Following the events of September 2001, we realize that our customers are concerned about the security of their drinking water. We urge the public to report any suspicious activities at any utility facilities, including treatment plants, pumping stations, tanks, fire hydrants, etc. to 615-896-9022

### Think before you flush!

Flushing unused or expired medicines can be harmful to your drinking water. Properly disposing of unused or expired medication helps protect you and the environment. Keep medications out of Tennessee's waterways by disposing in one of our permanent pharmaceutical take back bins. There are nearly 100 take back bins located across the state, to find a convenient location please visit: <https://tdeconline.tn.gov/rxtakeback/>

## Lead in Drinking Water

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Lewisburg water system is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact Lewisburg water system at 931-359-6831. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

## Lead Service Line Inventory

A Lead Service Line Inventory has been completed for our system and is accessible by contacting our office during regular business hours.

# Water Quality Data

## What does this chart mean?

**MCLG:** Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**MCL:** Maximum Contaminant Levels are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

**MRDL:** Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of disinfectants is necessary for the control of microbial contaminants

**MRDLG:** Maximum Residual Disinfectant Level Goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Discretionary language regarding the use of averages to report levels of some contaminants.

**AL - Action Level,** or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.

Parts per million (ppm) or Milligrams per liter (mg/l) – explained as a relation to time and money as one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - explained as a relation to time and money as one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**RTCR – Revised Total Coliform Rule.** This rule went into effect on April 1, 2016 and replaces the MCL for total coliform with a Treatment Technique Trigger for a system assessment.

Most of the data presented in this table is from testing done between January and December of 2025

Contaminant	Violation Y/N	Level Detected	Range of Detection	Date of Sample	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (RTCR)*	N	0		2025		0	TT Trigger	Naturally present in the environment
Turbidity <sup>1</sup>	N	0.08	.03- .08	2025	NTU	N/A	TT	Soil runoff
Copper <sup>2</sup>	N	90 <sup>th</sup> % =0.0320	0.0023-0.1370	2025	ppm	1.3	AL = 1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead <sup>2</sup>	N	90 <sup>th</sup> % = <2.0	<2.0- <2.0	2025	ppb	0	AL = 15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	10.2		2025	ppm	N/A	N/A	Erosion of natural deposits; used in water treatment
TTHM Total Trihalo-methanes	N	50.35 LRAA <sup>4</sup>	14.70 – 76.50	2025	ppb	0	80	By-product of drinking water chlorination
HAA5 Total Haloacetic Acids	N	41.93 LRAA <sup>4</sup>	13.10 – 70.30	2025	ppb	0	60	By-product of drinking water chlorination
Chlorine	N	1.76 AVE.	0.80– 3.40	2025	ppm	MRDLG = 4	MRDL = 4	Water additive used to control microbes.
TOC <sup>3</sup> (Total organic Carbon)	N	1.61	1.42-1.88	2025	ppm	TT	TT	Naturally present in the environment.
Nitrate	N	0.146		2025	ppm	10	10	Runoff from fertilizer use.
Atrazine	N	1.3		2025	ppb	3	3	Runoff from herbicide used on row crops
2,4-D	N	0.87		2025	ppb	70	70	Runoff from herbicide used on row crops

<sup>1</sup>100 % of our samples were below the turbidity limit. Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system.

<sup>2</sup>During the most recent round of Lead and Copper testing, only 0 out of 30 households sampled for copper contained concentrations exceeding the action level. 0 out of 30 tested for lead exceeded action level. Tests are performed every three years.

<sup>3</sup>TT-Treatment Technique, or a required process intended to reduce the level of a contaminant in drinking water. We met the Treatment Technique requirement for (TOC) Total Organic Carbon in 2025.

<sup>4</sup>LRAA: Locational running annual average, the average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.